


LINE DIAGRAM - LVS - RRU-X-UNV-FM - UL924 w/ ENLIGHTED CONTROL UNIT

PARTS LIST

CONTROL UNIT -- CU-4E-FMH ENLIGHTED, INC
 UL924 DEVICE -- RRU-X-UNV-FM LVS
 0-10V DRIVER

1. Blue wire provides CU relay bypass for AC to driver ensuring that light has power (N.C.)
2. Blue/Orange and Brown/Orange wires ensure dimming circuit is open during emergency condition (N.O.)
3. Driver must go to full on when 0-10V is absent



NOTE:
 Install in accordance with National and Local Electrical Codes in compliance with AHJ requirements.

enlighted
 A Siemens Company
 930 Benecia Ave
 Sunnyvale, CA 94085
 www.enlightedinc.com
 855-874-1692

REV # 93-03190-01